



જૂનાગઢ મ્યુનિસિપલ કોર્પોરેશન

“સ્વામી વિવેકાનંદભવન” આઝાદ ચોક જૂનાગઢ-૩૬૨૦૦૧

ફોન નં.૦૨૮૫-૨૬૨૨૦૮૯, ફેક્સ નં.૦૨૮૫-૨૬૫૧૫૧૦

ઈ-મેલ- municipalcorporationjund@yahoo.co.in



Test Report

Test Report No :- <u>I</u>	<u>Chudasama Titendrabhai</u>
Sample ID :- <u>-</u>	Sample Submitted by :- <u>Titendrabhai</u>
Main Source :- <u>Surface water</u>	Date of Sample Receipt :- <u>1/9/22</u>
Location :- <u>Gandhigram</u>	Analysis starting date :- <u>2/9/22</u>
District :- <u>Junagadh</u>	Analysis completion date :- <u>3/9/22</u>
	Group :- <u>water</u>
	Sample Type :- <u>Drinking water</u>

Kindly find here with the Analytical Result

Sr. No.	Parameter	Unit	Analytical Value
1	Colour	Hazen	
2	Odour	—	<u>Agreeable</u>
3	Taste	—	<u>Agreeable</u>
4	Turbidity	NTU	<u>3.1</u>
5	pH at 25°C	—	<u>7.4</u>
6	Conductivity at 25°C	$\mu\text{S/cm}$	<u>-</u>
7	Total Dissolved Solids	mg/l	<u>655</u>
8	Total Hardness (as CaCO ₃)	mg/l	<u>296</u>
9	Calcium (as Ca ²⁺)	mg/l	<u>83.2</u>
10	Magnesium (as Ca ²⁺)	mg/l	<u>51.71</u>
11	Chloride (as CT)	mg/l	<u>520</u>
12	Sulphate (as SO ₄ ⁻²)	mg/l	<u>-</u>
13	Nitrate (as NO ₃ ⁻)	mg/l	<u>-</u>
14	Fluoride (as F ⁻)	mg/l	<u>-</u>
15	Total Alkalinity (as CaCO ₃)	mg/l	<u>320</u>

Checked By:


Executive Engineer
Water Works Department
Junagadh Municipal Corporation

Dharagadh filter plant, mulawada, junagadh-362001



જૂનાગઢ મ્યુનિસિપલ કોર્પોરેશન

“સ્વામી વિવેકાનંદભવન” આઝાદ ચોક જૂનાગઢ-૩૬૨૦૦૧

ફોન નં.૦૨૮૫-૨૬૨૨૦૮૯, ફેક્સ નં.૦૨૮૫-૨૬૫૧૫૧૦

ઈ-મેલ- municipalcorporationjund@yahoo.co.in



Test Report

Test Report No :- 2	Mesuriya Jagdishbhai
Sample ID :- -	Sample Submitted by :- Jagdishbhai
Main Source :- Surface water	Date of Sample Receipt :- 9/9/22
Location :- Aeditya nagar	Analysis starting date :- 9/9/22
District :- Junagadh	Analysis completion date :- 10/9/22
	Group :- water
	Sample Type :- Drinking water

Kindly find here with the Analytical Result

Sr. No.	Parameter	Unit	Analytical Value
1	Colour	Hazen	
2	Odour	—	Agreeable
3	Taste	—	Agreeable
4	Turbidity	NTU	1.4
5	pH at 25°C	—	7.3
6	Conductivity at 25°C	μS/cm	—
7	Total Dissolved Solids	mg/l	968
8	Total Hardness (as CaCO ₃)	mg/l	408
9	Calcium (as Ca ⁺²)	mg/l	86.4
10	Magnesium (as Ca ⁺²)	mg/l	78.14
11	Chloride (as CT)	mg/l	500
12	Sulphate (as SO ₄ ⁻²)	mg/l	—
13	Nitrate (as NO ₃ ⁻)	mg/l	—
14	Fluoride (as F ⁻)	mg/l	—
15	Total Alkalinity (as CaCO ₃)	mg/l	564

Checked By:


Executive Engineer
Water Works Department
Junagadh Municipal Corporation

Dharagadh filter plant, mulawada, junagadh-362001



જૂનાગઢ મ્યુનિસિપલ કોર્પોરેશન

“સ્વામી વિવેકાનંદભવન” આઝાદ ચોક જૂનાગઢ-૩૬૨૦૦૧

ફોન નં.૦૨૮૫-૨૬૨૨૦૮૯, ફેક્સ નં.૦૨૮૫-૨૬૫૧૫૧૦

ઈ-મેલ- municipalcorporationjund@yahoo.co.in



Test Report

Test Report No :- 3	Meswariya Jagdishbhai
Sample ID :- -	Sample Submitted by :- Jagdishbhai
Main Source :- surface water	Date of Sample Receipt :- 13/9/22
Location :- gangotri nagar	Analysis starting date :- 13/9/22
District :- Junagadh	Analysis completion date :- 14/9/22
	Group :- water
	Sample Type :- Drinking water

Kindly find here with the Analytical Result

Sr. No.	Parameter	Unit	Analytical Value
1	Colour	Hazen	
2	Odour	—	Appreciable
3	Taste	—	Appreciable
4	Turbidity	NTU	3.8
5	pH at 25°C	—	6.5
6	Conductivity at 25°C	μS/cm	—
7	Total Dissolved Solids	mg/l	1112
8	Total Hardness (as CaCO ₃)	mg/l	340
9	Calcium (as Ca ²⁺)	mg/l	113.6
10	Magnesium (as Ca ²⁺)	mg/l	55.01
11	Chloride (as CT)	mg/l	320
12	Sulphate (as SO ₄ ²⁻)	mg/l	—
13	Nitrate (as NO ₃ ⁻)	mg/l	—
14	Fluoride (as F ⁻)	mg/l	—
15	Total Alkalinity (as CaCO ₃)	mg/l	540

Checked By:


Executive Engineer
Water Works Department
Junagadh Municipal Corporation

Dharagadh filter plant, mulawada, junagadh-362001



જૂનાગઢ મ્યુનિસિપલ કોર્પોરેશન

“સ્વામી વિવેકાનંદભવન” આઝાદ રોક જૂનાગઢ-૩૬૨૦૦૧

ફોન નં.૦૨૮૫-૨૬૨૨૦૮૯, ફેક્સ નં.૦૨૮૫-૨૬૫૧૫૧૦

ઈ-મેલ- municipalcorporationjund@yahoo.co.in




Test Report

Test Report No :- 4	Rathod Chanabhai
Sample ID :- —	Sample Submitted by :- Chanabhai
Main Source :- Surface water	Date of Sample Receipt :- 19/9/22
Location :- Jashipur	Analysis starting date :- 19/9/22
District :- Junagadh	Analysis completion date :- 20/9/22
	Group :- water
	Sample Type :- Drinking water

Kindly find here with the Analytical Result

Sr. No.	Parameter	Unit	Analytical Value
1	Colour	Hazen	
2	Odour	—	Agreeable
3	Taste	—	Agreeable
4	Turbidity	NTU	2.6
5	pH at 25°C	—	7.1
6	Conductivity at 25°C	μS/cm	—
7	Total Dissolved Solids	mg/l	946
8	Total Hardness (as CaCO ₃)	mg/l	332
9	Calcium (as Ca ²⁺)	mg/l	120
10	Magnesium (as Ca ²⁺)	mg/l	51.52
11	Chloride (as CT)	mg/l	328
12	Sulphate (as SO ₄ ²⁻)	mg/l	—
13	Nitrate (as NO ₃ ⁻)	mg/l	—
14	Fluoride (as F ⁻)	mg/l	—
15	Total Alkalinity (as CaCO ₃)	mg/l	568

Checked By:


Executive Engineer
Water Works Department
Junagadh Municipal Corporation

Dharagadh filter plant, mulawada, junagadh-362001