



જૂનાગઢ મ્યુનિસિપલ કોર્પોરેશન

“સ્વામી વિવેકાનંદભવન” આઝાદ ચોક જૂનાગઢ-૩૬૨૦૦૧

ફોન નં.૦૨૮૫-૨૬૨૨૦૮૯, ફેક્સ નં.૦૨૮૫-૨૬૫૧૫૧૦

ઈ-મેલ- municipalcorporationjund@yahoo.co.in



Test Report

Test Report No :- ૪	Cratesha Bhavabhai
Sample ID :- -	Sample Submitted by :- Bhavabhai
Main Source :- Surface water	Date of Sample Receipt :- ૭/૭/૨૨
Location :- padariya filter plant	Analysis starting date :- ૭/૭/૨૨
District :- Junagadh	Analysis completion date :- ૮/૭/૨૨
	Group :- water
	Sample Type :- Drinking water

Kindly find here with the Analytical Result

Sr. No.	Parameter	Unit	Analytical Value
1	Colour	Hazen	
2	Odour	—	Agreeable
3	Taste	—	Agreeable
4	Turbidity	NTU	1.9
5	pH at 25°C	—	૭.૦
6	Conductivity at 25°C	μS/cm	—
7	Total Dissolved Solids	mg/l	1042
8	Total Hardness (as CaCO ₃)	mg/l	460
9	Calcium (as Ca ²⁺)	mg/l	92
10	Magnesium (as Ca ²⁺)	mg/l	89.4
11	Chloride (as CT)	mg/l	378
12	Sulphate (as SO ₄ ²⁻)	mg/l	—
13	Nitrate (as NO ₃ ⁻)	mg/l	—
14	Fluoride (as F ⁻)	mg/l	—
15	Total Alkalinity (as CaCO ₃)	mg/l	510

Checked By:

Dharagadh filter plant, mulawada, junagadh-362001



જૂનાગઢ મ્યુનિસિપલ કોર્પોરેશન

“સ્વામી વિવેકાનંદભવન” આઝાદ ચોક જૂનાગઢ-૩૬૨૦૦૧

ફોન નં.૦૨૮૫-૨૬૨૨૦૮૯, ફેક્સ નં.૦૨૮૫-૨૬૫૧૫૧૦

ઈ-મેલ- municipalcorporationjund@yahoo.co.in




Test Report

Test Report No :- 6	Sida Kasambhai
Sample ID :- —	Sample Submitted by :- kasambhai
Main Source :- surface water	Date of Sample Receipt :- 5/7/22
Location :- Dharagadh filter plant	Analysis starting date :- 5/7/22
District :- Junagadh	Analysis completion date :- 6/7/22
	Group :- water
	Sample Type :- Drinking water

Kindly find here with the Analytical Result

Sr. No.	Parameter	Unit	Analytical Value
1	Colour	Hazen	
2	Odour	—	Agreeable
3	Taste	—	Agreeable
4	Turbidity	NTU	1.3
5	pH at 25°C	—	7.4
6	Conductivity at 25°C	μS/cm	—
7	Total Dissolved Solids	mg/l	1584
8	Total Hardness (as CaCO ₃)	mg/l	580
9	Calcium (as Ca ²⁺)	mg/l	176
10	Magnesium (as Ca ²⁺)	mg/l	96.17
11	Chloride (as CT)	mg/l	512
12	Sulphate (as SO ₄ ²⁻)	mg/l	—
13	Nitrate (as NO ₃ ⁻)	mg/l	—
14	Fluoride (as F ⁻)	mg/l	—
15	Total Alkalinity (as CaCO ₃)	mg/l	348

Checked By:


Executive Engineer
Water Works Department
Junagadh Municipal Corporation

Dharagadh filter plant, mulawada, junagadh-362001